



2845 BRISTOL CIRCLE,  
OAKVILLE, ONTARIO L6H 7H7

**HYDRAULIC PROCEDURE**

Proc. #:	<b>602-700P</b>		
Revision #:	0	Pages: 1	1 of 1
Date:	August 23, 2007		

Description:	Advance Notification of Water flows to the Goffstown Police Dispatch
Written by:	R. Tomat/ S. Fairfield

During the August 2007 Emergency Action Plan (“EAP”) annual meeting with the local emergency responders, coordinated by the facility operator, the Police Chief requested Algonquin Power’s assistance with respect to notifying their office on increasing river flows during adverse weather conditions.

- This procedure is provided in order to instruct personnel on this “Advanced Notification” program.
- This proactive notification has been agreed to by the Division Manager and Regional Operation Manager
- This procedure does not circumvent the Greggs Falls generating station Emergency Action Plan. The operator must still adhere to the facility EAP.

Requirement:

1. The operator of the facility will notify the Goffstown Police dispatcher when river flows reach 3000 cubic feet per second.
2. Once this notification has been provided the operator must immediately communicate (via fax or e-mail) to the Regional Manager ([Ralph.tomat@algonquinpower.com](mailto:Ralph.tomat@algonquinpower.com)) and the Regulatory Affairs office ([sean.fairfield@algonquinpower.com](mailto:sean.fairfield@algonquinpower.com)) of the notification that was taken.